Addendum #1 IFB 22-18



CITY OF SOMERVILLE, MASSACHUSETTS Department of Purchasing JOSEPH A. CURTATONE MAYOR

To: Bidders of Fire Hydrants and Related Parts

From: Andrea Caruth, Deputy Chief Procurement Officer

Date: December 1, 2021

Re: Response to Requests for Information

Addendum No. 1 to IFB 22-18

This addendum documents responses to all requests for information (RFIs) submitted by prospective applicants to this IFB.

Bidders are hereby informed that Contract Documents for the above-mentioned contract are modified, corrected, and/or supplemented as follows and the Addendum No. 1 becomes part of the Contract Documents.

SPECIFICATIONS

- 19. **REMOVE** Fire hydrant shall be the Clow Medallion as manufactured by the Clow Valve Company or approved equal.
 - **This addendum changes specifications. Failure to acknowledge this addendum will result in bid disqualification.**

NAME OF COMPANY / INDIVIDUAL:						
ADDRESS:						
CITY/STATE/ZIP:						
TELEPHONE/FAX/E	MAIL:					
SIGNATURE OF AUTHORIZED INDIVIDUAL:						
ACKNOWLEDGEMENT OF ADDENDA:						
Ado	dendum #1	#2	#3	#4		

Addendum #1 IFB 22-18

#	Question	Answer
1	We are bidding as an "or equal" on the hydrants with American AVK, made in the USA product.	The City has provided material specifications in the bid package. The bid pricing should be based on products that meet those specifications.
	Can we also submit a price for the AVK repair kits and extensions?	Bidders submit a proposed product after the award and not with the submission of a bid. After the Award, the bidder will submit the proposed product. Subsequently, the City will determine whether the bid item is equal to that named in the specification.
2	For section 2 of items (the hydrant repair kits, extension kits, and wrenches)- can you guys take parts from an aftermarket shop such as hydrant repair parts or do these kits need to come straight from the manufacturer?	Due to the City's experience with aftermarket parts we prefer and want any repair parts or tools to come from the manufacturer.